



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.: FSR/IND/WB/FES/20182019/47235

Date : 21-11-2025

From :
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
GAURAV BHUWALKA
2A, NANDA MULICK LANE, KOLKATA- 700006

Sub : Renewal of Fire Safety Certificate for the occupancy of an existing G+V storied under group of Educational Building in the name & style of "Sri Chaitanya Techno School" at premises no.- 2A, Nanda Mullick Lane, Kolkata- 700 006

Memo No.: FSR/IND/WB/FES/20182019/47235

This is in reference to your AIN 211912506300007276 dated 26-Aug-2025 regarding Renewal of Fire Safety Certificate for the occupancy of an existing G+V storied under group of Educational Building in the name & style of "Sri Chaitanya Techno School" at premises no.- 2A, Nanda Mullick Lane, Kolkata- 700 006

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300007276

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the drive way.
2. The Interior finish decoration of the building shall be made with low flame spread material as per norms.
3. To eliminate risk of Fire Hazards, Good House Keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and Tear in them. If required the old electrical lines shall be replaced with new electrical lines, cables Shall always be laid in M.S. conduit pipes continuously bonded to the earth.
5. The existing lifts shall be designed as fire lifts for use in case of emergency.
6. Collapsible lift are not allowed, it must be enclosed type.
7. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.
8. The employee and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
9. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the Occupants of the building.
10. First-Aid Firefighting system shall be provided as per I.S. Specifications.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them to perfectly good working condition at all times.
12. Periodical flashing of water from the hydrant and hose reel hose shall be done to maintain the Efficient working performance of the system.
13. Fire Safety Audit shall be conducted a regular interval and to be recorded in the Fire Prevention Maintenance Register.
14. Emergency lighting system (battery backup) to be installed in the stair case for the safe Evacuation.
15. A fire control room including a close circuit T.V. system shall have to be properly maintained which will observe all the floors of the building.
16. All security staff of the building needed more training for fire safety measures.
17. Housekeeping shall have to maintain properly all the time inside the building.
18. Transformer & switch gears room shall have to protect with Co2 or DCP as per norms.
19. Fire license shall have to obtain for storing and processing with LPG or other highly combustible articles if used.
20. All pumps, detection, firefighting system shall have to keep in auto mode round the clock.

This Renewal of Fire Safety Certificate is valid for three years and to be renewed before the date of expiry.

Every three year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services,

Valid Upto : 19-Nov-2028

Memo No.:

FSR/IND/WB/FES/20182019/47235



Signature valid

Digitally Signed.
Name: NIHAR RAMJAN ROY
Date: 21-Nov-2023 14:52:15
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300007276